



STATE OF NEVADA						OFFICE USE ONLY	
DIVISION OF WATER RESOURCES						Log No.	103520
WELL DRILLER'S REPORT						Permit No.	
						Basin	212
<b>PRINT OR TYPE ONLY</b>						<i>Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340</i>	
<b>DO NOT WRITE ON BACK</b>						NOTICE OF INTENT NO. 31424	
1. OWNER Clark County Aviation			ADDRESS AT WELL LOCATION McCarren Airport Terminal 3				
MAILING ADDRESS P.O. Box 11005			5757 Wanye Newton Boulevard, Las Vegas, NV				
Las Vegas, Nv			Subdivision Name:		County:		
2. LOCATION <u>NE</u> 1/4 <u>NE</u> 1/4 Sec <u>34</u> T <u>21</u> N/S R <u>61</u> E		Latitude		UTM E		NAD 27	
PERMIT/WAIVER No. DW-1243A		162-34-502-010		Longitude		N x NAD 83/WGS 84	
Issued by Water Resources		Parcel No.		162-35-101-018			
3. WORKED PERFORMED			4. PROPOSED USE <u>DEWATER</u>			5. WELL TYPE	
New Well		Replace		Recondition		Domestic	
Deepen		x Other		Dewatering Well		Municipal/Industrial	
				Irrigation		Test	
				Monitor		Stock	
				Cable		Rotary	
				Air		x Other	
				RVC		Auger Bucket	
6. LITHOLOGIC LOG				9. WELL CONSTRUCTION			
Material		Water		From		To	
		Strata				Thick-ness	
Well #7407							
N486875.8 E631710.9							
Clayey Gravel				0		11	
Caliche - white/hard				11		13	
Fat Clay-with sand, gravel				13		18	
Silty Clayey Sand - red,brown				18		22	
Clayey Gravel, cemented lenses				22		34	
Sandy Fat Clay, brown to tan				34		39	
Caliche - moderate cemented				39		49	
Caliche - hard				49		51	
Well #7408							
N486875.8 E631810.9							
Clayey Gravel				0		11	
Caliche - white/hard				11		14	
Fat Clay-with sand, gravel				14		18	
Silty Clayey Sand - red,brown				18		21	
Clayey Gravel, cemented lenses				21		34	
Sandy Fat Clay, brown to tan				34		47	
Caliche - moderate cemented				47		49	
Caliche - hard				49		51	
Date started: 17-Jul				20		07	
Date completed: 7/17/2007				20		07	
7. Water Level				10. DRILLER'S CERTIFICATION			
Static water level: 26'		feet below land surface		This well was drilled under my supervision and the report is true to the best of my knowledge.			
Artesian Flow:		G.P.M.		P.S.I.			
Water Temperature: °F				Name Griffin Dewatering Corp			
Quality:				Contractor			
8. WELL TEST DATA				Address 536 E. Maitland Street			
TEST METHOD:		Bailer		Pump		Air Lift	
		G.P.M.		Draw Down		Time (Hours)	
				(Feet Below Static)			
				Contractor Ontario, Ca 91761			
				Nevada contractor's license number			
				issued by the State Contractor's Board C-23 0031246			
				Nevada driller's license number issued by the			
				Division of Water Resources, the on-site driller M-2264			
				Signed <i>[Signature]</i> <b>DENR/DWR RECEIVED</b>			
				By driller performing actual drilling on site of contractor			
				Date 7/31/06			
				USE ADDITIONAL SHEETS IF NECESSARY			

AUG 03 2007