

033711

2 wells

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 103533  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31453

1. OWNER PENSKE TRUCK LEASING  
MAILING ADDRESS Route 10 Green Hills  
PO Box 563 Reading, Pennsylvania  
2. LOCATION NW 1/4 SE 1/4 Sec. 28 T. 20  
PERMIT NO. 139-28-703-001  
Issued by Water Resources Parcel No. Subdivision Name

ADDRESS AT WELL LOCATION 1132 W. Bonanza Rd. Las Vegas, NV  
Las Vegas, NV  
N OR 615 Clark County

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt & Tuff		0	1	1
Silty Sand w/ clay		1	10	9
Caliche		9	11	2
Silty Sand w/ clay		11	18	7
Sandy silt	R	18	21	3
Silty SAND w/ clay		21	25	4

8. WELL CONSTRUCTION

Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
11.50 Inches 0 Feet 25 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>Sch 40</u>	<u>PVC</u>	<u>0</u>	<u>25</u>

Perforations:  
Type perforation Factory slot  
Size perforation .020  
From 10 feet to 25 feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 7  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 7 feet to 25 feet

DEVELOPER  
APPROVED  
JUL 25 2007  
LAS VEGAS OFFICE

① 36° 10' 41.6" N  
115° 9' 25.8" W  
② 36° 10' 44.1" N  
115° 9' 23.5" W  
DATUM WSG 84

9. WATER LEVEL

Static water level 17 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Poor

Date started 06/26, 2007  
Date completed 06/26, 2007

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Eagle Drilling Services LLC  
Address 7150 Placid St  
Las Vegas, NV 89119  
Nevada contractor's license number issued by the State Contractor's Board 51266  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 07/25/07