

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30757

1. OWNER Angel Flores ADDRESS AT WELL LOCATION 1290 S. Cottonwood Ln. Amargosa Valley, Nv. 89020
 MAILING ADDRESS H.C. 70 Box 537-2 Amargosa Valley, Nv. 89020 N OR 48 E NYE County
 2. LOCATION NE 1/4 SW 1/4 Sec. 1 T. 17 PERMIT NO. 19-531-027
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Snd & gravel</u>		<u>0</u>	<u>85</u>	<u>85</u>
<u>gravelly</u>	<u>1st</u>	<u>85</u>	<u>110</u>	<u>25</u>
<u>Snd w/ gravel</u>		<u>110</u>	<u>170</u>	<u>60</u>
<u>voids in cly, & limestone layers</u>		<u>170</u>	<u>195</u>	<u>25</u>
<u>Bottom of well</u>			<u>195</u>	

8. WELL CONSTRUCTION
 Depth Drilled 195 Feet Depth Cased 195 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 195
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>195</u>
<u>8</u>	<u>steel</u>	<u>.188</u>		<u>7</u>

 Surface protective casing:
 Perforations:
 Type perforation Machined
 Size perforation 4R, 1 1/2" x 3" every 12"
 From 95 feet to 115 feet
 From 135 feet to 155 feet
 From 175 feet to 185 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 195 feet

9. WATER LEVEL
 Static water level 87 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4/26 2007
 Date completed 4/28 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Cook Drilling Co. Contractor
 Address H.C. 70 Box 543 Amargosa Valley, Nv. 89020 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 5376-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
 Signed Red Johnson
 By driller performing actual drilling on site or contractor
 Date 5/20/07