

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30756

1. OWNER Gary Reno ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 329 Bridle Way  
Amargosa Valley, NV 89020 Crystal, NV 89060  
 2. LOCATION SE 1/4 SE 1/4 Sec. 7 T. 17 N. R. 52 E. Nye County  
 PERMIT NO. 21-161-14R 21-161-14 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Snd + gravel</u>		<u>0</u>	<u>35</u>	<u>35</u>
<u>gravel</u>	<u>1st</u>	<u>35</u>	<u>50</u>	<u>15</u>
<u>gravel w/ clay layers</u>		<u>50</u>	<u>110</u>	<u>60</u>
<u>snd + gravel</u>		<u>110</u>	<u>120</u>	<u>10</u>
<u>bottom of well</u>			<u>120</u>	

G.P.S.  
36° 29.257 N  
116° 09.884 W WGS 84

**LAS VEGAS OFFICE**

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
12 1/4 Inches From 0 Feet To 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>PVC</u>		<u>0</u>	<u>120</u>
<u>8"</u>	<u>steel</u>	<u>.188</u>	<u>0</u>	<u>7</u>

Perforations:  
 Type perforation Machined  
 Size perforation 4 R, 1/8" x 3" every 12"  
 From 60 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50'  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 120 feet

9. WATER LEVEL  
 Static water level 38 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Cook Drilling Co. Contractor  
 Address H.C. 70 Box 543 Contractor  
Amargosa Valley, NV 89020  
 Nevada contractor's license number issued by the State Contractor's Board 5376-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160  
 Signed Red Johnson  
 By driller performing actual drilling on site or contractor  
 Date 5/20/07

Date started 4/22, 2007  
 Date completed 4/24, 2007

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift  

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>DOWNHOLE</u>		
<u>RECEIVED</u>		
<u>AUG 28 2007</u>		

**LAS VEGAS OFFICE**