STATE OF NEVADA

DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 103563
Permit No.
Basin 092A

NOTICE OF INTENT NO. 56973

1. OWNER Richard Allen
MAILING ADDRESS 1255 Goldstone Reno, NV. 89506

ADDRESS AT WELL LOCATION 1255 Goldstone Reno, NV. 89506
Subdivision Name: N/A County: Washoe

2. LOCATION ~~SW¼SW¼~~ NE SE Sec25T22N/ R18E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 079-352-16 (Parcel. No.)

Latitude 39.74180 Longitude 119.90486
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG/Brown Clay		0	76	76
Brown Clay		76	100	24
Brown Clay Stone		100	150	50
Grey Clay Stone		150	225	75
Grey/ Green rock	X	225	325	100

N 39.741913
W 119.903848 NAD27

2007 AUG -1 AM 11:30
STATE ENGINEER'S OFFICE

Date started: 6-30, 20 07
Date completed: 7-07-, 20 07

7. Water Level
Static water level: 172 feet below land surface
Artesian Flow: None G.P.M. None P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	40	PWL 260	3

9. WELL CONSTRUCTION
Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 3/4 Inches	0 Feet	20 Feet
10 Inches	20 Feet	325 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8 steel	14	.188	-2	15
6 5/8 PVC	4.07	PVC	15	325

Perforations:
Type of perforation Mill Slot
Size of perforation .032
From 255 feet to 315 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 63 ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 63 to 325 ☐ Pumped ☒ Poured
Type: 3/8 pea
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Miller & Son's Drilling (CONTRACTOR)
Address P.O. Box 8056 (CONTRACTOR)
Reno, NV. 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 7-27-07

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com