STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103577
Permit No.
Basin 122

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60161

1. OWNER RICHARD TESTA
MAILING ADDRESS 1507 SWEETWATER LANE
FARMINGTON, UT 84025

ADDRESS AT WELL LOCATION 14 MILES S. OF WELLS
WEST OF HWY 93
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION NW ¼ NW ¼ Sec 28 T 35N N/S R 62 E
PERMIT/WAIVER No. 008-320-016
Issued by Water Resources Parcel No.

Latitude 40.892851
Longitude 114.983663
UTM E 11T 0669861 [X] NAD 27
N 4528608 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	5	5
CLAY & SAND		5	22	17
GRAVEL		22	85	63
BROWN CLAY		85	90	5
GRAVEL	90	90	160	70

Date started: 12-Jul , 20 07
Date completed: 18-Jul , 20 07

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	135

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 115 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[X] Cement Grout 0 to 50 [X] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 135 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 48 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC.
Contractor
Address P. O. BOX 850
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020682
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2335
Signed
By driller performing actual drilling on site or contractor
Date 7/27/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY