COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103589
Permit No.
Basin 105

NOTICE OF INTENT NO. 60298

1. OWNER CHRIS CORDES
MAILING ADDRESS 1055 HWY 88 S.
GARDNERVILLE , NV 89406

ADDRESS AT WELL LOCATION 786 CENTERVILLE LN
GARDNERVILLE , NV 89460

2. LOCATION SW ¼ SW ¼ Sec 7 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) 1220-07-002-010 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
COURSE DG SANDS		3	26	23
BROWN CLAY		26	83	57
GRAY CLAY		83	105	22
COURSE DG SANDS				
SILTY CLAY		105	160	55

N 38.911009
N 119.786704 NAD27

GPS INFO: NAD 83
38.91091*N
119.78770*W

Date started 7/12 , 20 07
Date completed 7/13 , 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
254	30	3 HRS

STATE ENGINEER'S OFFICE
2007 AUG 14 AM 9:55

8. WELL CONSTRUCTION
Depth Drilled 160' Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8sdr 21	4.06	.316	20	160
		.316		

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 120 feet to 140 feet
From 150 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 2 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 8/4/07