WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103591
Permit No.
Basin 101

NOTICE OF INTENT NO. 59883

1. OWNER Michael Peroni
MAILING ADDRESS
ADDRESS AT WELL LOCATION 17405 Lahontan Dam Rd. Fallon, NV

2. LOCATION SE ¼ NE ¼ Sec. 11 T. 18 N/S R. 26 E. Churchill Co. County
PERMIT NO. (Issued by Water Resources) 006-122-79 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulder Gravel & Cobbles		0	30	30
Sand & Gravel		30	60	30
Brown Clay & Gravel		60	232	172
Green Clay & Gravel		232	238	6
Green Clay		238	275	37
Black Fractured Volcanic Rock	✓	275	300	25

GPS, WGS 84
N 39°26.412
W 119°01.702

N39.440301
W119.027384 NAD27

Date started July 20 /07, 20
Date completed July 24 /07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3 GPM	300' PWL	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 301' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	300'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13 lbs	.188	+1'	20'
6 5/8	SDR21	PVC	20'	300'

Perforations:
Type perforation Saved
Size perforation 1/8 X 3
From feet to feet
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60' feet to 300' feet

9. WATER LEVEL
Static water level 161 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality turbid

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc. (Contractor)
Address PO Box 599 (Contractor)
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel L. Leach (By driller performing actual drilling on site or contractor)
Date Aug 13 /07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627