

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 103597  
Permit No. ....  
Basin 083

NOTICE OF INTENT NO 59657

1. OWNER **Edward Martinez** ADDRESS AT WELL LOCATION **4401 Six Mile Canyon Rd**  
MAILING ADDRESS **PO Box 763** Latitude N 39.30344 WGS 84  
**Virginia City, NV 89440** Longitude W 119.56660  
2. Location **SE 1/4 SE 1/4 25 Sec T17 N R21 E** Storey County  
PERMIT NO. PARCEL NO. **04-321-55** SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	<input checked="" type="checkbox"/> Air	Other	Mud


6. LITHOLOGIC LOG					8. WELL CONSTRUCTION				
Material	Water/Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)	Depth Cased	From	To
Native & rock.		0	10	10	11	inches	0	feet	50
DG, broken rock.		10	90	80	8 3/4	inches	50	feet	380
White rock.		90	220	130		inches		feet	feet
White, purple, green rock.		220	320	100					
Broken rock & fractures		320	380	60					
					CASING SCHEDULE				
					Size O.D.	Weight/Ft.	Wall Thickness	From	To
					0 (Inches)	(Pounds)	(Inches)	(Feet)	Feet
					0 6 5/8	12.94	188	+1 1/2	380
					Perforations::				
					0	Type Perforation	Factory		
					0	Size perforation	3/32 x 3"		
					0	From	320 feet to	380	feet
					0	From	feet to		feet
					0	From	feet to		feet
					0	From	feet to		feet
					0	From	feet to		feet
					0	From	feet to		feet
					0	Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:
					0	Depth of Seal	50 feet		Neat Cement
					0		Pumped		<input checked="" type="checkbox"/> Cement Grout
					0		<input checked="" type="checkbox"/> Poured		Concrete Grout
					0	Gravel Packed:	<input checked="" type="checkbox"/> Yes	No	
					0	From	50 feet to	380	feet
					9 WATER LEVEL				
					0	Static water level	130	feet below	land surface
					0	Artesian flow	0	GPM	0 P.S.I.
					0	Water Temperature	cold	Degrees F	Quality

N 39.303544  
W 119.565604 NAD83

2007 AUG 15 11:10:53  
STATE ENGINEERS OFFICE

Date started 7-23 -07  
Date completed 7-31 -07

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
10	40		.5
15	110		.5
20	270		.5
25	250		.5

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
NV Contractors No. **14170**  
NV Driller's Lic (on site) **2187**  
Signed   
By driller performing actual drilling on site or contractor  
Date 8-9 -07