REPORT NO. A07.58

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 103603
PERMIT NO.
BASIN Ø83

NOTICE OF INTENT NO. 59712

1. OWNER Dennis Sullivan
MAILING ADDRESS 14444 Bercaw LN, San Jose CA 95124

ADDRESS OF WELL 1410 Scorpion Rd
VC Highlands, NV

2. WELL LOCATION SE 1/4 NW 1/4 SEC. 30 T 18 R 21 E Storey COUNTY

PERMIT NO PARCEL NO 003-321-46 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Red VR- Red Clay				
Greenish Brown Dirt-Gray Clay		0	18	18
Multi Color VR-Yellow Gray Clay		18	29	11
Blue VR w/Black Specs		29	37	8
Thick Gray Blue Clay-Blue VR		37	50	13
Blue Green VR & Clay		50	150	100
Dark Purple VR	X	150	220	70
Prple/Maroon VR w/White Specs		220		
Spec of Green Rock		220	300	80
Blue VR with White Specs		300	350	50
Thick Maroon Colored Clay-Blue		350		
VR with White Specs		350	409	59
Hard Red/Blue Basalts Fractured		409	430	21
Black Basalts		430	470	40
Blue Basalts with White & Red		470		
Specs-Orange VR	X	470	510	40
Red VR- Red Clay		510	515	5
Blue VR w/White Specs Fractured		515	598	83

Notes : WGS-84 GPS: Latitude: N39 23.947 Longitude: W119 40.160

N 39.379223
W 119.668333 NAD27

Date Started 08/06/2007 Date Completed 08/13/2007

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	9		3.50

8. WELL CONSTRUCTION

Depth Drilled 598 Depth Cased 597

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 398 Feet
77/8 Inches 398 Feet 598 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8"	12.92	.188	+3'	597'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 557 Feet to 597 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 597 Feet

9. WATER LEVEL
Static Water Level 100 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed Roger Mitchell
By driller performing actual drilling on site or contractor

Dated August 14 2007

STATE ENGINEER'S OFFICE
2007 AUG 9 AM 11:12