STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 103606
Permit No.
Basin 692B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56363

1 OWNER Debby Longobardo
MAILING ADDRESS 11585 Chesapeake Dr
Reno NV 89506

ADDRESS AT WELL LOCATION 11585 Chesapeake Dr
Reno NV 89506
Subdivision Name:
County: Washoe

2 LOCATION NW ¼ SE ¼ Sec 15 T 21 N/S R 18 E
Latitude N39.40904
Longitude W119.50147
UTM E
N
☐ NAD 27 ☒ NAD 83/WGS 84
PERMIT/WAIVER No. 1080-361-02 Issued by Water Resources
SW Parcel No.

3 TYPE OF WELL
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

Is this well being plugged because a replacement well was drilled?
If yes, what is replacement well NO?

Is there an existing well log?
If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.5	188	0	120

Existing Perforations:
Type of perforation Factory
Size of perforation 1/16 X 31/2

From	feet to	feet
100	120	

5 WATER LEVEL
Static water level 96 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

6 Additional Notes or Comments

N 39.6618 45
W 119.834775 NAD27

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? ☒ yes ☐ no
If well was not cleaned out to total depth, please explain why:

Was the well contaminated? ☐ yes ☒ no
Was the casing pulled? ☐ yes ☒ no
Was the casing over drilled? ☐ yes ☒ no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: Mills Knife

From	feet to	feet	Number of perfs per linear foot
100	35		5

8 WELL PLUGGING MATERIALS
Material Used

From	feet to	feet		
120	0		☒ Pumped	☐ Poured
			☐ Pumped	☐ Poured
			☐ Pumped	☐ Poured
			☐ Pumped	☐ Poured
			☐ Pumped	☐ Poured
			☐ Pumped	☐ Poured

Neat Cement Fluid Weight 96 lbs/gal 7.9
Bentonite Grout % bentonite
Date Started 8/7/2007
Date Completed 8/7/2007

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Knoblock & Sons Pump and Supply
Contractor
Address 5425 Spanish Moss
Contractor
Sparks NV 89436
Nevada contractor's license number issued by the State Contractor's Board 49162
Nevada driller's license number issued by the Division of Water Resources, the on-site driller AB-2219
Signed
By driller performing actual drilling on site or contractor
Date 8/16/2007

USE ADDITIONAL SHEETS IF NECESSARY

2007 AUG 20 AM 11:44 STATE ENGINEER'S OFFICE