

Log No. 103623

Permit No. \_\_\_\_\_

Basin. 049

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60147

1. OWNER B.G.B. INVESTMENTS ADDRESS AT WELL LOCATION Not established

MAILING ADDRESS 555 Pine St Elko, NV 89801 864 Clark Ave

2. LOCATION SE 1/4 NW 1/4 Sec 23 T. 32 N/R. 55 E Elko County \_\_\_\_\_

PERMIT NO. N/A Issued by Water Resources Parcel No. 027-039-003 Subdivision Name Lucky Nugget Ranch's Unit #1

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
Boulders		1	3	2
Clay, sand, gravel		3	18	15
Boulders		18	20	2
Clay, gravel, boulders		20	25	3
Sand clay		25	115	90
sand, gravel, clay	✓	115	120	5
Clay		120	150	30
Clay, sand gravel	✓✓✓	150	165	15
Clay		165	169	3
N 40.64566 NAD27				
N 115.75087				
G.P.S.				
40.64467 N				
115.74927 W				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

From	To
12 Inches	0 Feet 5.2 Feet
8 Inches	5.2 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	12.92	1.88	0	

Perforations:  
 Type perforation Torch cut  
 Size perforation \_\_\_\_\_  
 From 118 feet to 125 feet  
 From 195 feet to 165 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 168 feet

9. WATER LEVEL  
 Static water level 108 feet below land surface  
 Artesian flow no G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Math Drilling Co. Contractor  
 Address 203 Pine St Elko, NV 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10819  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632  
 Signed James Y. Math By driller performing actual drilling on site or contractor  
 Date 9-7-07

Date started 8-30-07  
 Date completed 9-7-07

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	4pm 20	1 hr