COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103641
Permit No.
Basin 162

NOTICE OF INTENT NO. 30586

1. OWNER Raymond E. Romero
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3321 S. Prairie St.

2. LOCATION SW ¼ NE ¼ Sec 34 T 20-S N R 53 E Nye County

PERMIT NO. (Issued by Water Resources) | 40-671-11 (Parcel No.) | Calvada Valley Ut: 4-A, Blk: 16, Lot : 1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Brown Clay/Gran. Caliche | | 4 | 14 | 10 |
| Brown Clay | | 14 | 43 | 29 |
| Brown Clay/Caliche | | 43 | 97 | 54 |
| Brown Clay | X | 97 | 200 | 103 |

Location: WGS 84
N 36° 10.258'
W 116° 00.259'

Elevation: 2580'
Accuracy: 15'

DCNR/DWR RECEIVED AUG 20 2007 LAS VEGAS OFFICE

Date started August 15, 20 07
Date completed August 15, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 200 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 3.92 | .28 | 0 | 180 |
| | | | | |

Perforations:
Type perforation Saw Cut
Size perforation 1/4" width 8" long
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC. (CONTRACTOR)
Address P.O. BOX 56 (CONTRACTOR)
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563A
Nevada driller's license number issued by the Division of Water Resources, ~~the on-site driller~~ 1324
Signed Jim Pike
By driller performing actual drilling on site or contractor
Date August 16, 2007


Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com