STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103652
Permit No.
Basin 064

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51346

1. OWNER Eric Taylor
MAILING ADDRESS HC61 Battle Mountain NV 89820

ADDRESS AT WELL LOCATION
Subdivision Name: County: Lander

2. LOCATION NE ¼ SW ¼ Sec 9 T 34N N/S R 45 E
PERMIT/WAIVER No. 74414T, 74415T
Issued by Water Resources 76293 Parcel No.

Latitude
Longitude
UTM E 507097 [x] NAD 27
N 4520069 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [x] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sandstone		2	15	13
Limestone		15	35	20
Limestone with Clay		35	70	35
Blue Clay		70	105	35
Sandstone with clay		105	125	20
Sandstone , Lava with clay		125	160	35
Cemented Basalt cobbles w clay		160	180	20
Limestone with sandstone		180	200	20
Cemented fractured lava	X	200	240	40

N40.833526
W116.915828 NAD27

Date started: 25-May , 20 07
Date completed: 1-Jun , 20 07

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
32	Inches	0	Feet	15	Feet
26	Inches	15	Feet	210	Feet
25	Inches	210	Feet	240	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		0.188	+1	20
6.625		0.316	20	240

Perforations:
Type of perforation Saw cut
Size of perforation 1/8" x 4"
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[x] Concrete Grout 0 to 54 [ ] Pumped [x] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 54 to 280 [ ] Pumped [x] Poured
Type: 5/8" Minus
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 77 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & Pump Service (Contractor)
Address 3040 Callahan St (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 0020578
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2208
Signed (By driller performing actual drilling on site or contractor)
Date 6/22/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY