WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103667
Permit No.
Basin 203

NOTICE OF INTENT NO. 25424

1. OWNER BOB WILLARD, BARB BAILEY
MAILING ADDRESS HCR 34, BOX 8
CALIENTE, NV 89008
ADDRESS AT WELL LOCATION 555 MABLE TRAIL CALIENTE NV 89008

2. LOCATION NW ¼ NE ¼ Sec. 3 T. 3 N/S R. 67 E/W LINCOLN County
PERMIT NO. Issued by Water Resources
131-90-08 Parcel No.
BRADLEY RANCH Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL & ROCKS		0	9'	9'
BROWN SANDY CLAY		9'	14'	5'
WHITE TUFF		14'	22'	8'
BROWN SANDY CLAY		22	145	123
HARD RED SANDSTONE		145	166	21
BROWN SANDY CLAY		166	182	16
HARD RED CLAY		182	195	13
SAND & GRAVEL	YES	195	220	25
COBBLES	YES	220	227	7
BROWN CLAY		227	233	6
SAND & GRAVEL	YES	233	242	9
RED SANDY CLAY		242	247	5

Date started 09 - JUNE 2007, 19
Date completed 12 - AUGUST 2007, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14	21	2
GPS		
N	37° 42.768',	WGS84
W	114° 28.412	

8. WELL CONSTRUCTION
Depth Drilled 247 Feet Depth Cased 247 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8" Inches	0 Feet	52 Feet
7 7/8" Inches	52' Feet	247 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"		1	+1	247

Perforations:
Type perforation VERTICAL
Size perforation 1/8" x 6 x 4 ROWS
From 187 feet to 247 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 247 feet to 50 feet

9. WATER LEVEL
Static water level 183 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 63 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBB INC. Contractor
Address 6411 DEER SPRING WAY Contractor
LAS VEGAS NV 89131
Nevada contractor's license number issued by the State Contractor's Board 0020301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2064
Signed [signature] By driller performing actual drilling on site or contractor
Date 19 AUGUST 2007

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627