WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103671
Permit No.
Basin 207

NOTICE OF INTENT NO. 56 051

1. OWNER Orvan Maynard
MAILING ADDRESS Box 64
Lund NV 89317

ADDRESS AT WELL LOCATION none Lot 15 Block 2
NAD27 N 38° 52' 20.0"
W 115° 01' 17.8"

2. LOCATION NE ¼ SE ¼ Sec. 29 T. 12 N/S R. 62 E. White Pine County
PERMIT NO. 70908 Issued by Water Resources
013-113-07 Parcel No.
Lund Ten Acre Plat Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Clay		0	10	
Soft Lime Stone-Clay		10	11	
Silty Clay		11	18	
gravel	water	18	23	5
Clay		23	40	
Cemented gravel	water	40	46	6
Clay		46	53	
Cemented gravel		53	60	
Silty Clay		60	70	
gravel - Clay	water	70	85	15
Clay		85	89	
gravel	water	89	92	3
Clay - gravel		92	110	
Silty Clay		110	116	
gravel - Clay	water	116	135	39
Silty Clay		135	166	
gravel - Lime Clay	water	166	174	8
Silty Clay		174	184	
N38.872222				
W115.021556 NAD27				

Date started May 2, 2007
Date completed July 23, 2007

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80	5	1

8. WELL CONSTRUCTION
Depth Drilled 184 Feet Depth Cased 184 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
22 Inches		0 Feet	50 Feet
16 Inches		50 Feet	184 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	4	184

Perforations:
Type perforation Mill
Size perforation ⅛ x 2.5" x 32 rows
From feet to feet
From 57 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 60 feet

9. WATER LEVEL
Static water level 26 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling Contractor
Address Po Box 64 Lund NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 042224
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1554
Signed Orvan Maynard By driller performing actual drilling on site or contractor
Date Aug 20 - 07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627