STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103687
Permit No.
Basin 069

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59486

1. OWNER Bill Jonkey
MAILING ADDRESS PO Box 2253 Minden, NV 89423

ADDRESS AT WELL LOCATION Greeley Crossing
Paradise Valley, NV 89426
Subdivision Name: County: Humboldt

2. LOCATION ~~N1/2~~ SE¼ SE¼ Sec 25 T42N / R40E
Latitude N41°29.195 UTM E ☐ NAD 27
Longitude W117°24.420 N ☒ NAD 83/WGS 84

PERMIT/WAIVER NO. 004-401-29
Issued by Water Resources Parcel. No.

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cobles Sand		0	3	3
sand stone brown		3	55	52
black sand		55	60	5
sand stone black		60	82	22
gray green sand stone		82	87	5
tan clay & fine gravel sand		87	95	8
boulder		95	98	3
sand stone redish		98	105	7
fine gravel sand redish		105	115	10
clay sand white		115	138	23
fine sand & gravel		138	155	17
clay sand		155	159	4
red fine gravel sand		159	170	11
cobles sandstone		170	210	40
sandstone fine		210	270	60
course sand fine gravel	X	270	295	25

N 41.486698
W 117.406033 NAD 27

Date started: April 26, 20 07
Date completed: May 3, 20 07

7. Water Level
Static water level: 232 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: warm °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		10

2007 MAY 17 AM 10:36

9. WELL CONSTRUCTION
Depth Drilled 295 Feet Depth Cased 295 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	295 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	1.88	+1	20
6.625	4.06	.316	20	295

Perforations:
Type of perforation factory cut
Size of perforation 050
From 255 feet to 295 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 295 ☐ Pumped ☒ Poured
Type: 3/8"
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site or contractor
Date May 11, 2007

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com