Corrected

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103689
Permit No.
Basin 177

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59455

1. OWNER Frehner Construction
MAILING ADDRESS 4040 Frehner Rd
Las Vegas, NV 89030

ADDRESS AT WELL LOCATION Clover Valley
Subdivision Name: County: Elko

2. LOCATION NW ¼ NW ¼ Sec 34 T 36N N/S R 62 E
PERMIT/WAIVER No. C-237 Issued by Water Resources
Parcel No.

Latitude 40.966.11N
Longitude 114.96055W
UTM E N
☐ NAD 27 ☐ NAD 83/WGS 84 NAD83

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other ☒ Plugging

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pulled Casing to 120'				
Hole filled with Bentonite Chips				
Rest of casing removed from				
hole. Filled remainder of hole with				
concrete. (All casing removed				
from hole)				
N 40.966199				
W 114.969667 NAD27				

Date started: 19-Apr , 20 07
Date completed: 25-Apr , 20 07

7. Water Level
Static water level: 65 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX			

STATE ENGINEERS OFFICE
2007 MAY -7 AM 11:57
RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		188	+2	18
6	SDR-17		0	200

Perforations:
Type of perforation Screen
Size of perforation 0.05
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout to ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☒ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 200 ☐ Pumped ☐ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☐ Yes ☐ No 0 to 50 ☐ Pumped ☐ Poured
Type: 3/8 Kiwk plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1584
Signed
By driller performing actual drilling on site or contractor
Date 5-3-07

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY