WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 10313
Permit No.
Basin 198

NOTICE OF INTENT NO. 59059

1. OWNER Rick Thompson
MAILING ADDRESS 10185 Sweet Grass Rd Henderson NV 89002
ADDRESS AT WELL LOCATION 10 miles East of Pioche in Dry Valley

2. LOCATION S/W ¼ S/W ¼ SE ¼ Sec 36 T. 1 N R. 69 E. Lincoln County
PERMIT NO. 0 Issued by Water Resources | Parcel No. 06-301-44 | Subdivision Name Frechner

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand Boulders | | 0 | 110 | 110 |
| clay- Boulders | | 110 | 150 | 40 |
| gravel-sand | X | 150 | 170 | 20 |
| clay | | 170 | 172 | 2 |

[redacted]

GPS N 37° 53.726
W 114° 18.526

Datum WG 584

N37.895472
W 114.307935 NAD27

Date started 1-11-07, 20
Date completed 1-13-07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | | 2 |

2007 JAN 19 AM 11:09

8. WELL CONSTRUCTION
Depth Drilled 172 Feet Depth Cased 172 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 10 5/8 | 0 | 172 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | PVC | Sch 40 | 0 | 172 |

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 3"
From 93 feet to 173 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 172 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028864
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 1-17-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627