STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103726
Permit No.
Basin 021

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58356

1. OWNER MIKE CHRISTOPHER
MAILING ADDRESS PO Box 197
Gerlach, NV 89412

ADDRESS AT WELL LOCATION 40.804 119.50962

2. LOCATION SW ¼ NE ¼ Sec 29 T 34N N/S R 22 E
PERMIT/WAIVER No. _____ *Issued by Water Resources* Parcel No.

Latitude 40.804
Longitude 119.50962
UTM E
N
☒ NAD 27
☐ NAD 83/WGS 84
Subdivision Name: *County:* Washoe

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other.....

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed Granite		0	7	7
Sandy Clay		7	20	13
Brown Clay		20	60	40
Green Clay		60	110	50
Brown Clay		110	120	10
Brown Rock		120	150	30
Basalt		150	160	10
Vol		160	190	30
Basalt		190	240	50
Vol		240	260	20
Basalt		260	280	20
Vol		280	300	20
Clay & Vol		300	320	20

WL 060224

Date started 12-Dec , 20 06
Date completed 14-Dec , 20 06

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3HR

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	320	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	90

Perforations:
Type of perforation MILL SLOT
Size of perforation 0.09
From 90 feet to 310 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 320 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources Nevada, Inc. dba Humboldt Drilling & Pump
Contractor
Address 4975 W. Winnemucca Blvd., Winnemucca, NV 89445
Contractor
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2099
Signed Judi Leach Office
By driller performing actual drilling on site or contractor
Date 1/5/2007

STATE ENGINEER'S OFFICE
2007 JAN -8 PM 2:54
RECEIVED

(Rev. 12-05)

USE ADDITIONAL SHEETS IF NECESSARY