WASHOE #

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 103737
Permit No.
Basin 087

NOTICE OF INTENT NO 59009

1. OWNER **Dylan Mattole**
MAILING ADDRESS **5320 Cognac Court**
Reno, NV

ADDRESS AT WELL LOCATION **5695 Rock Farm Road**
Latitude N 39.23.642
Longitude W 119.49.106 WGS 84

2. Location **NE** 1/4 **SW** 1/4 Sec 26 T **18** N R **19** E **Washoe** County
PERMIT NO. PARCEL NO. ~~050-260-04~~ 150-260-14 SUBDIVISION NAME

3. WORK PERFORMED
New Well, Replace, Recondition, Deepen, **X** Abandon, Other

4. PROPOSED USE
X Domestic, Irrigation, Test, Municipal/Industrial, Monitor, Stock

5. WELL TYPE
Cable, **X** Rotary, RVC, **X** Air, Other, Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blew well to 350'				0
				0
Perfed from 25' to 350'				0
				0
Installed termie to 350' &				0
pumped neat cement to				0
surface.				0
				0
We did get returns.				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

N 39.394141
W 119.817429 NAD27

RECEIVED
2007 APR 26 AM 11:35
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled feet Depth Cased feet
HOLE DIAMETER (BIT SIZE)

	From	To
inches	0 feet	feet
inches	feet	feet
inches	feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
6 5/8	12.9	.188	-1	350

Perforations::
Type Perforation **Air**
Size perforation **1/4 x 1/2**
From **25** feet to **350** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
Surface Seal **X** YES No
Depth of Seal **350** feet
x Pumped
Poured
Gravel Packed: Yes No
From feet to feet

Seal Type:
x Neat Cement
Cement Grout
Concrete Grout

9 WATER LEVEL
Static water level **325** feet below land surface
Artesian flow GPM **0** P.S.I.
Water Temperature **cool** Degrees F Quality **unkn**

Date started **10/27** -07 06
Date completed **10/31** -07 06

7. WELL TEST DATA
TEST METHOD: Bailer Pump **x** Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
4850 Joule St.
Reno, NV 89502
NV Contractors No. **14170**
NV Driller's Lic (on site) **2121**
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date 11/7 -07 06