WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103741
Permit No.
Basin 137B

NOTICE OF INTENT NO. 59413

1. OWNER Pat + Pasty Waits
MAILING ADDRESS never to drill
ADDRESS AT WELL LOCATION 40 Globe Circle Gillman Springs, NV

2. LOCATION NW ¼ NW ¼ Sec. 10 T. 16 N/S R. 44 E. Lander Co. County
PERMIT NO. W 00M07-00 (Issued by Water Resources) 004-011-11 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobbles + Gravel-Boulders Clay		0	117	117
Gray Clay		117	130	23
Boulders-Gravel		130	150	20
Clay		156	163	
Cobbles + Gravel		163	170	7
Boulders-Gravel		170	200	30
Sand-Gravel		200	240	40

GPS,
N 39° 16.219'
W 117° 01.576
Elevation 5719' feet.

Date started 4/13/07, 20
Date completed 4/20/07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100 GPM	Air Lift	3 Hr

N 39.270399
W 117.025342 NAD27

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 241' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	240'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	23 lbs	.186	+1	20'
6 5/8	SDR 21	PVC	20	240'

Perforations:
Type perforation Sawed
Size perforation 1/8 x 3"
From 180' feet to 200' feet
From 220' feet to 240' feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100' feet to 240' feet

9. WATER LEVEL
Static water level 66' feet below land surface
Artesian flow Cold G.P.M. P.S.I.
Water temperature °F Quality turbid

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Beach Drilling Inc Contractor
Address PO Box 599 Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] By driller performing actual drilling on site or contractor
Date 4/21/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627