WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103743
Permit No.
Basin 132B

NOTICE OF INTENT NO. 59411

1. OWNER ~~Lea~~ LETHA Robertson
MAILING ADDRESS

ADDRESS AT WELL LOCATION HC 60 Box 77212 Round Mtn NV 89045

2. LOCATION NE ¼ NW ¼ Sec. 2 T. 14 N N/S R. 43 E. Nye Co County

PERMIT NO. Issued by Water Resources | Parcel No. 10-451-15 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	15'	15'
Sand & Cobbles		15	30'	15'
Coarse Sand				
D-6		30'	57	27'
Gravel		57	63	6'
Clay (Gray Color)		63	89	26'
Brown Clay		89	100'	11'
Sand & Gravel		100	120	20'

GPS, WGS84
N 39° 06.473'
W 117° 06.990'
Elevation 5482'

Date started 4/10/07, 20
Date complated 4/11/07, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	50 Gpm		2 Hrs
N 39,108014			
W 117,115575	NAD27		

STATE ENGINEERS OFFICE
2007 APR 24 AM 11:07
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 121' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.13 lbs	.188	+1	20'
6 5/8	SDR 21		20	120'

Perforations:
Type perforation Sawed
Size perforation 1/8 x 3"
From 115 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 120' feet

9. WATER LEVEL
Static water level 3' feet feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc
Contractor
Address PO Box 599
Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature]
By driller performing actual drilling on site or contractor
Date 4/21/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627