REPORT NO. A07.08

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

I

LOG NO. 103752
PERMIT NO.
BASIN 103

NOTICE OF INTENT NO. 59491

1. OWNER Bob Bryant
MAILING ADDRESS P.O. Box 20824, Carson City, NV 89721

ADDRESS OF WELL 2000 Hwy 341
Mound House, NV

2. WELL LOCATION SW 1/4 NW 1/4 SEC. 16 T 16 R 21 E Lyon COUNTY

PERMIT NO ____ PARCEL NO 16-121-02 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

| MATERIAL | STRATA | FROM | TO | THICKNESS |
|---|---|---|---|---|
| Reddish Brown Dirt VR | | 0 | 1 | 1 |
| Bl & Grn Hard Basalts Fractured | | 1 | 156 | 155 |
| Some Gray & Green Clay Mixed | | 156 | 165 | 9 |
| Bl & Grn Fractured Hard Basalts | | 165 | 178 | 13 |

RECEIVED 2007 FEB -8 PM12:37 STATE ENGINEER'S OFFICE

Notes: WGS-84 GPS: Latitude: N39 15.098 Longitude: W119 38.410

N 39.251737
W 119.639169 NAD27

Date Started 01/29/2007 Date Completed 02/01/2007

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

| | GPM | DRAWDOWN | TIME (HRS) |
|---|---|---|---|
| | 20+ | | 1/2 |
| | | | |
| | | | |

8. WELL CONSTRUCTION

Depth Drilled 178' Depth Cased 178'

HOLE DIAMETER (BIT SIZE)

10 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 178 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

| Size OD | Weight/Ft | Wall Thickness | From | To |
|---|---|---|---|---|
| 6 5/8" | 12.92 | .188 | +2' | 178' |
| | | | | |
| | | | | |
| | | | | |

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 138 Feet to 178 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50'
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 178 Feet

9. WATER LEVEL
Static Water Level 117 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed Roger M Thrall
By driller performing actual drilling on site or contractor

Dated February 7. 2007