WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103773
Permit No.
Basin 179

NOTICE OF INTENT NO. 59421

1. OWNER Randall Reber
MAILING ADDRESS 4525 Blue Magic Way, N. Las Vegas, NV 89031
ADDRESS AT WELL LOCATION 50 West 55th South St., Ely, NV 89301

2. LOCATION SE ¼ SE ¼ Sec. 15 T 16 N/S R 63 E White Pine County
PERMIT NO. Issued by Water Resources | APN 10-510-15 Parcel No. 3 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 1 | 1 |
| Cemented Gravel | | 1 | 45 | 44 |
| Clay & Gravel | | 45 | 65 | 20 |
| Cemented Gravel | | 65 | 90 | 25 |
| Clay | | 90 | 100 | 10 |
| Cemented Gravel | | 100 | 120 | 20 |
| Water Bearing Sand & Grvl. | x | 120 | 125 | 5 |
| Hard Pan | | 125 | 150 | 25 |
| Water Bearing Gravel | x | 150 | 155 | 5 |
| Clay & Gravel | | 155 | 175 | 20 |
| Hard Pan | | 175 | 200 | 25 |

N 39.246028
W 114.861722 NAD27

WGS 84
N39° 14' 45.7"
W114° 51' 42.2"
Elev. 6,473

Date started July, 6, 2007
Date completed July, 17, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 65 | 62 | 1 1/2 |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 10 5/8 | 0 | 200 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 12.92 | .188 | 0 | 200 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory
Size perforation 1/8" x 2 1/2" 6 Rows
From 120 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 118 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Ave. (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rick Lewis By Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date August, 24, 2007

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627