

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Permit No. _____
 Basin. 102

NOTICE OF INTENT NO. 59881

1. OWNER Jim Clinton ADDRESS AT WELL LOCATION 5150 5th St
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SW 1/4 Sec. 11 T. 17 N/S R. 25 E Lyon Co County silver springs
 PERMIT NO. 017-226-07 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>3'</u>	<u>3</u>
<u>Clay Sand</u>		<u>3</u>	<u>137</u>	<u>134</u>
<u>Sand clay & gravel</u>		<u>137</u>	<u>145</u>	<u>9</u>
<u>Gray clay</u>		<u>145</u>	<u>210</u>	<u>65</u>
<u>Layers gravel sand & clay</u>		<u>210</u>	<u>240</u>	<u>30</u>
<u>6ps W65 84</u>				
<u>N 39° 20, 733</u>				
<u>W 119° 09, 154</u>				
<u>N 39, 345651</u>				
<u>W 119, 151581 NAD27</u>				

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 241 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11" Inches To 240' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13 lbs</u>	<u>1.88</u>	<u>7</u>	<u>20</u>
<u>6 5/8</u>	<u>p/c</u>	<u>5.02</u>	<u>20</u>	<u>240</u>

Perforations:
 Type perforation Sawed
 Size perforation 18 x 2"
 From _____ feet to _____ feet
 From 200' feet to 230' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes, No Seal Type:
 Depth of Seal 60 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 60' feet to 240' feet

9. WATER LEVEL
 Static water level 33' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Turbid

Date started 8/9/07, 20_____
 Date completed 8/19/07, 20_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30 Gpm</u>	<u>4 hrs</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Jack Pulling Jr Contractor
 Address PO Box 579 Contractor
Silver Springs, NV 89429
 Nevada contractor's license number 31841 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
 Signed Jack Pulling Jr
 By driller performing actual drilling on site or contractor
 Date Aug 27/07