


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **56723**

1. OWNER **Reynan & Bardis, LLC**  
 MAILING ADDRESS **1380 Greg St., Suite 230 Sparks, NV 89431**

ADDRESS AT WELL LOCATION **Approximately 300' south of the corner of McCart St. and Miller Lane and 50' west (Jackson Ranch)**

2. LOCATION **SE 1/4 NW 1/4 Sec. 14 T 20N** N/S R **24E E** **Lyon** County

PERMIT NO. **21-041-03** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
There was 1, 4" monitor well and 1, 2" monitor well at this location. We measured the 4" monitor well at 130' deep and the static water level at 84'. We installed 126' of tremme pipe and mixed 18 bags of cement with approx. 100 gallons of water and pumped the well full from the bottom to the surface. The 6" protective cover was cut off at ground surface. We then measured the 2" pvc monitor well at 40' deep with no water in the well. We pumped the well full to the surface. Original well log attached for the 4" well. GPS: 39 36.249 North & 119 15.36 West, 4166' elevation.				
Plugging of Log # 73289				
N 39.604256 W 119.255008 NAD27				

8. WELL CONSTRUCTION  
 Depth Drilled **130'** Feet Depth Cased **130'** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		sch. 40	130'	+1'
2"		sch. 40 pv	+1'	40'

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_

From	feet to	feet

Surface Seal:  Yes  No  
 Depth of Seal **130'**  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level **4", 84'** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Carson Pump** Contractor  
 Address **P.O. Box 20159** Contractor  
**Carson City, NV. 89721**  
 Nevada contractor's license number issued by the State Contractor's Board **39920**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1482**  
 Signed *Don Strangor*  
 By driller performing actual drilling on-site or contractor  
 Date **1/13/2007**

Date started **12/5/2006**, 19  
 Date completed **12/5/2006**, 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

STATE ENGINEERS OFFICE  
 14:11 PM 1-14-07  
 RECEIVED