WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103790
Permit No.
Basin 179

NOTICE OF INTENT NO. 57120

1. OWNER Robinson Nevada Mining Co
MAILING ADDRESS 4232 West White Pine Co Rd 44 Ruth Nevada 89319
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ Sec. 9 T. 16 ⊗S R. 62 E. White Pine County
PERMIT NO. NEV 92105 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY gravel W/SAND		0	10	10
well graded gravel		10	20	10
SANDY SILT W/ gravel		20	30	10
SILTY SAND W/gravel		30	40	10
well graded SAND W/SILT		40	50	10
SANDY SILT W/gravel		50	60	10
well graded SAND		60	90	30
CLAYEY gravel W/SAND		90	100	10
SILTY SAND W/gravel		100	110	10
well graded SAND W/CLAY		110	140	30
SILTY SAND W/gravel		140	150	10
well graded SAND with SILT		150	160	10
well graded SAND and gravel		160	180	20
poorly graded SAND W/CLAY		180	190	10
well graded SAND W/SILT		190	200	10
well graded SAND W/gravel		200	210	10
well graded SAND W/SILT + gravel		210	230	20
well graded SAND		230	240	10
well graded gravel	247	240	250	10
Bed Rock		250	256	4
UTM Nad 27				
673177 East	NAD83			
4348375 North				
N 39.267498				
W 114.991711 NAD27				

Date started NOV 14, 2006
Date complated NOV 17, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 257 Feet Depth Cased 257 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	+0	257

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 in		SCH 80 PVC	+2	257

Perforations:
Type perforation Mill
Size perforation 0.020
From 237 feet to 257 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20 FT
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 235 feet to 257 feet

9. WATER LEVEL
Static water level 247 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC EXPLORATION + WELLS (Contractor)
Address 9580 COUNTY RD 93B (Contractor)
ZAMORA CA 95698
Nevada contractor's license number issued by the State Contractor's Board 0012850 2
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2263
Signed Cliff Rawlett (By driller performing actual drilling on site or contractor)
Date NOV 17 2006

STATE ENGINEER'S OFFICE
2007 JAN -5 AM 11:03
RECEIVED

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627