

N 53 01.710  
W 114° 28.836' WGS 84

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 103800  
Permit No. 1  
Basin 202

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55917

1. OWNER Wayne Lister ADDRESS AT WELL LOCATION 8-Mile Ranch  
MAILING ADDRESS P.O. Box 402 Pioche, NV 89043  
2. LOCATION SW 1/4 SW 1/4 Sec 16 T 2 N R 67 E Lincoln County  
PERMIT NO. 006-201-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Clay</u>		<u>0</u>	<u>42</u>	<u>42</u>
<u>Brown Clay w/ string sand</u>		<u>42</u>	<u>64</u>	<u>22</u>
<u>Cemented sand</u>		<u>64</u>	<u>67</u>	<u>3</u>
<u>Brown Clay w/ string sand</u>		<u>67</u>	<u>88</u>	<u>21</u>
<u>Cemented sand</u>		<u>88</u>	<u>92</u>	<u>4</u>
<u>Brown Clay w/ sand</u>		<u>92</u>	<u>195</u>	<u>103</u>
<u>Gravel</u>		<u>195</u>	<u>200</u>	<u>5</u>

N 38.626676  
W 114.480595 NMD27

RECEIVED  
2007 JAN -5 AM 10:54  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 200 Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1/4</u>	<u>-2</u>	<u>200</u>

Perforations:  
Type perforation mill slot  
Size perforation 1/8 x 3  
From 100 feet to 120 feet  
From 140 feet to 160 feet  
From 180 feet to 200 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 57  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 57 feet to 200 feet

Date started 13 Dec 2006  
Date completed 29 Dec 2006

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>1hp</u>	<u>25</u>	<u>19</u>	<u>12 hrs</u>

9. WATER LEVEL  
Static water level 57 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name 8-Mile Drilling Contractor  
Address P.O. Box 402 Contractor  
Pioche, NV 89043  
Nevada contractor's license number issued by the State Contractor's Board 0029502  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1441  
Signed Wayne Lister  
By driller performing actual drilling on site or contractor  
Date 29 Dec 2006