

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



office use only  
Log No. 103803  
Permit No. ....  
Basin 094

NOTICE OF INTENT NO 56468

1. OWNER **Robert Valceschini**  
MAILING ADDRESS **10250 Silver Knolls Blvd.  
Reno, NV 89506-8535**

ADDRESS AT WELL LOCATION **4268 Deer Lodge Rd.**  
Latitude N 39 deg 47.562 1297  
Longitude W 119 deg 52.270 W6584

2. Location **NW 1/4 NE 1/4 Sec 8 T22 N R19 E**  
PERMIT NO. PARCEL NO. **079-382-83**

Washoe County

SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock and Red Clay		0	75	75
Gray Clay		75	675	600
Sand and Clay		675	775	100
Rock		775	825	50

8. WELL CONSTRUCTION

Depth Drilled **825 feet** Depth Cased **825 feet**  
HOLE DIAMETER (BIT SIZE)

	From	To	
11 inches	0 feet	60 feet	
8 3/4 inches	60 feet	825 feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	12.97	188	1 1/2	825

Perforations:

Type Perforation	Factory & air
Size perforation	1/4 & 3/32
From 0 feet to 600 feet	
From 600 feet to 825 feet	
From feet to feet	
From feet to feet	
From feet to feet	
From feet to feet	
From feet to feet	
Surface Seal	<input checked="" type="checkbox"/> YES No
Depth of Seal	58 feet
	Pumped
	<input checked="" type="checkbox"/> Poured
Gravel Packed:	<input checked="" type="checkbox"/> Yes No
From 58 feet to 825 feet	

Seal Type:  
Neat Cement  
 Cement Grout  
Concrete Grout

9. WATER LEVEL

Static water level **400 feet** below land surface  
Artesian flow **GPM 0 P.S.I.**  
Water Temperature **Degrees F** Quality **good**

N 39.792814  
W 119.870155 NAD27

RECEIVED  
2007 JAN -4 AM 11:09  
STATE ENGINEERS OFFICE

Date started **10/24 -06**  
Date completed **11/9 -06**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)			Time (hours)
3	100			.5
4	200			.5
5	300			.5
7	375			1.5

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**  
**4850 Joule St.**  
**Reno, NV 89502**

NV Contractors No. **14170**  
NV Driller's Lic (on site) **786**

Signed   
By driller performing actual drilling on site or contractor

Date **11/9 -06**