WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103812
Permit No.
Basin 087

NOTICE OF INTENT NO. 58062

1. OWNER Washoe County Department of Water Resources
MAILING ADDRESS 4930 Energy Way
Reno, NV 89702

ADDRESS AT WELL LOCATION 5305 Mill St. Reno, NV.
Approximately 1200' north of Coop esdtension building

2. LOCATION NW 1/4 NW 1/4 Sec. 16 T 19N N/S R 20E E Washoe County
PERMIT NO. 012-302-05 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This was a 2" pvc monitor well. Measured static water level at 13'. Depth of well at 28'. Installed 26' of 3/4" pvc and mixed 2 bags of Portland cement with 10 gallons of water and pumped in from bottom of well to surface. Protective cover was removed and casing cut off below ground level.				

Date started 10/20/2006, 19__
Date completed 10/20/2006, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
2007 JAN -5 AM 11:14
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 28' Feet Depth Cased 28' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch. 40	+1	28'

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 28'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 13' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump
Contractor
Address P.O. Box 20159
Contractor
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed
By driller performing actual drilling on-site or contractor
Date 1/4/2007

USE ADDITIONAL SHEETS IF NECESSARY