STATE OF NEVADA

DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 108823
Permit No.
Basin 070

NOTICE OF INTENT NO. 59488

1. OWNER **Wendy & Robert Kramer**
MAILING ADDRESS **PO Box 1355 Winnemucca, NV 89446**
SW

ADDRESS AT WELL LOCATION **6075 Drake Lane**
Winnemucca, NV 89445
Subdivision Name: *County:* **Humboldt**

2. LOCATION **SE¼SW¼** Sec**10**T**36N** / R**38E**
PERMIT/WAIVER NO. **10-171-06**
Issued by Water Resources Parcel. No.

Latitude **N41°00.279'** UTM E ☐ NAD 27
Longitude **W117°41.511'** N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	3	3
Gravel		3	10	7
Rock		10	13	3
Gravel		13	40	27
Clay		40	45	5
Course Gravel/Sand	x	45	90	45
Clay		90	105	15
Course Gravel		105	115	10
Clay		115	118	3
Sand & Fine Gravel	X	118	140	22

2007 JUN -6 AM 10:52

N 41.004762
W 117.690862 NAD27

Date started: **May 17**, 20 **07**
Date completed: **May 21**, 20 **07**

7. *Water Level*
Static water level: **55'** feet below land surface
Artesian Flow: **N/A** G.P.M. **N/A** P.S.I
Water Temperature: **Cool** °F
Quality: **Good**

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		5

9. *WELL CONSTRUCTION*
Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	**0** Feet	**140** Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	1.88	+1	20
6.625	4.06	.316	20	120

Perforations:
Type of perforation **Factory Cut Slot**
Size of perforation **050**
From **120** feet to **140** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No ~~3/8 50~~ to 140 ☐ Pumped ☒ Poured
Type: 3/4
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)
Address **10760 S. Grass Valley Rd.** (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* **021467**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **2083**
Signed Fred Anderson Drilling Inc.
By driller performing actual drilling on site or contractor
Date **May 30, 2007**

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com