

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 103853
 Permit No. _____
 Basin 102

NOTICE OF INTENT NO. 59401

1. OWNER John Collis ADDRESS AT WELL LOCATION 5900 Railroad
 MAILING ADDRESS P.O. Box 930, Silver Springs, NV 89429
 2. LOCATION SE 1/4 SE 1/4 Sec. 6 T. 17 N. S. R. 25 E. Lyon County
 PERMIT NO. N/A SW 17-084-10 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Clay		0	40	
Sand & gravel		40	100	
Big gravel & coarse sand	▼	100	158	
N39.362602 W 119.226963 NAD27				
39° 21.750 W 119° 13.317 W				

8. WELL CONSTRUCTION
 Depth Drilled 158 Feet Depth Cased 158 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____
10 5/8 Inches 0 Feet 158 Feet
 Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>7/8</u>	<u>71</u>	<u>20</u>
<u>6</u>		<u>S&P 21</u>	<u>20</u>	<u>158</u>

Perforations:
 Type perforation Saw cut
 Size perforation 5 1/16
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 140 feet to 158 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 60 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60 feet to 158 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature COLD °F Quality Clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lynch Drilling Contractor
 Address BX 599 Silver Springs NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 5-24-07

Date started 5-22-07 20 _____
 Date completed 5-23-07 20 _____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>300</u>	<u>80 ft</u>	<u>28:01 @ 2 HRS</u>