WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103889
Permit No.
Basin 099

NOTICE OF INTENT NO. 52997

1. OWNER Holler, Billy & Amy
MAILING ADDRESS 60 Quarthorse Cir Reno NV 89506
ADDRESS AT WELL LOCATION 60 Quarthorse Cir Reno NV 89506

2. LOCATION SE ¼ SE ¼ Sec. 10 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. Issued by Water Resources | 078 20102 Parcel No. | Sierra Rancho Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	15	15
Rock		15	47	32
Clay		47	53	6
Rock S.P.		53	275	222
Rock (Fract)	✓	275	280	5
Rock Gray		280	305	25
Rock (Fract)	✓	305	340	35
Clay Gray		340	342	2
N39.872956				
W 119.943345 NAD27				
N 39 87284				
W 119.94436	NAD83			

Date started 3/30, 2007
Date completed 5/19, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	300	6

8. WELL CONSTRUCTION
Depth Drilled 342 Feet Depth Cased 342 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
18	0	15
10 5/8	15	204
8 3/4	204	342

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	3/16	2+	342

Perforations:
Type perforation Saw slot
Size perforation 3/16 6 Around
From 262 feet to 282 feet
From 302 feet to 342 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 342 feet

9. WATER LEVEL
Static water level 102 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenski Drilling & Pump Co. (Contractor)
Address 15045 Red Rock Rd (Contractor)
Reno NV 89506
Nevada contractor's license number issued by the State Contractor's Board 50343
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed (By driller performing actual drilling on site or contractor)
Date 5/23/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627