WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103860
Permit No.
Basin 179

NOTICE OF INTENT NO. 51417

1. OWNER Kathy Smith
MAILING ADDRESS 3764 Pama Ln.
Las Vegas, NV 89120-2907

ADDRESS AT WELL LOCATION Tehama Creek Ranch
3815 East 1817th N. St.

2. LOCATION SE ¼ ~~SW~~ SE ¼ Sec. 22 T. 22 N/S R. 64 E. White Pine County
PERMIT NO. Issued by Water Resources
APN 08-350-05 Parcel No. 4
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sand & Gravel		2	5	3
Volcanics		5	168	163
Fractured Volcanics	x	168	169	1
Volcanics		169	345	176
Fractured Volcanics	x	345	392	47

N39.753794
W 114.719690 NAD27

WGS84
Lot. N39° 45' 13.4"
Long. W 114° 43' 14.0"
Elev. 6,242 ft.

Date started April 12, 2007
Date complated May 5, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1 50	107	2

8. WELL CONSTRUCTION
Depth Drilled 392 Feet Depth Cased 392 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	392 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	392

Perforations:
Type perforation Factory
Size perforation 1/8" x 2 1/2" 8 Rows
From 92 feet to ~~392~~ 392 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 392 feet

9. WATER LEVEL
Static water level 273 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. Contractor
Address 557 Ely Ave. Contractor
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rich Lewis By Jerald D. Christiansen
By driller performing actual drilling on site or contractor
Date June 11, 2007

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627