COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103874
Permit No.
Basin 105

NOTICE OF INTENT NO. 58261

1. OWNER MIKE & MAGGIE HAKANSSON
MAILING ADDRESS GARDNERVILLE , NV 89460
ADDRESS AT WELL LOCATION 628 WEST FORK VISTA LN GARDNERVILLE , NV 89460

2. LOCATION SE ¼ NE ¼ Sec 11 T 12 N R 19 E DOUGLAS County
PERMIT NO. (Issued by Water Resources) Parcel No. 1219-11-001-009 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
BROWN DG SANDS	X	3	9	6
COURSE DG SANDS		9	36	27
BROWN CLAY		36	102	66
SOFT DG SANDS		102	153	51
BROWN CLAY		153	159	6
COURSE DG SANDS	XXX	159	200	41

N38.918609
W119.808583
NAD27

GPS INFO: NAD 83
38.91851*N
119.80958*W

Date started 5/5 , 20 07
Date completed 5/6 , 20 07

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40+	60	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level FLOWS feet below land surface
Artesian flow 30 G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/2/07

2007 JUN 18 PM 1:11

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429