WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103876
Permit No.
Basin 141

NOTICE OF INTENT NO. 29946

1. OWNER ANTHONY & DIANE PERCHETTI
MAILING ADDRESS
ADDRESS AT WELL LOCATION LEON ST. & DAGO WAY BELMONT NV.

2. LOCATION SE ¼ NE ¼ Sec. 26 T. 9 N/S R. 45 E. NYE County
PERMIT NO. Issued by Water Resources | 004-534-11 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY & GRAVEL | | 0 | 35 | 35 |
| CEMENTED SAND & GRAVEL | | 35 | 52 | 17 |
| GRANITE W/FRACTURES | W.B. | 52 | 110 | 58 |
| N38.595954 | | | | |
| W 116.875671 NAD27 | | | | |
| NORTH AMERICAN 1983 | | | | |
| N. 38° 35' 147" | | | | |
| W 116° 52' 595" | | | | |

2007 JUN 20 AM 11:55

Date started 6-12, 2007
Date completed 6-13, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 3/4 Inches | 0 Feet | 110 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4½ | 2.36 | .248 | 0 | 110 |
| | | | | |

Perforations:
Type perforation SAW CUT
Size perforation ⅛ INCH BY 6 INCH
From 110 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 FT.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 110 feet to 50 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO. Contractor
Address P.O. BOX 3505 PAHRUMP Contractor
NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
Signed By driller performing actual drilling on site or contractor
Date 6-18-2007

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627