WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA 5
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 103886
Permit No.
Basin 212

NOTICE OF INTENT NO. 24694

1. OWNER COMMERCE ASSOCIATES LLC
MAILING ADDRESS 875 W. Warm Springs Rd. Henderson NV, 89011
ADDRESS AT WELL LOCATION Approx 0.2 miles S/W of Intersection of Olivia Pkwy & Olivia Pkwy.

2. LOCATION SE ¼ SW ¼ Sec. 32 T. 21 N/S R. 63 E. Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 16032401005 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Sonic

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Interbedded Sand & Gravel | | 0' | 12' | 12' |
| Muddy Creek Formation | ✓ | 12' | 35' | 23' |
| Interbedded Clay & Silt | | | | |

NAD 83
681573 E
3994252 N.

Date started 7-25-, 2007
Date completed 7-25-, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 Inches | 0 Feet | 35 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4" | 21b./ft. | Sch 40 0.474" | +3 | 15 |
| | | | | |

Perforations:
Type perforation Sch 40 Factory Cut
Size perforation .020
From 15 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 13
Placement Method: ☐ Pumped ☑ Poured
Seal Type: 3/8 chips
☐ Neat Cement 2'-13'
☐ Cement Grout 0'-2'
☑ Concrete Grout 2

Gravel Packed: ☑ Yes ☐ No
From 13 feet to 35 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bart Longyear Co. Contractor
Address 7773 W. Seldon Lane Peoria, AZ 85345 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2148
Signed Phillip E. C. By driller performing actual drilling on site or contractor
Date 8-20-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627