WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
213702
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

4 wells

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103910
Permit No.
Basin 222

NOTICE OF INTENT NO. 31464

1. OWNER Casa Blanca Resorts LLC
MAILING ADDRESS 899 W. Mesquite Blvd
Mesquite NV
ADDRESS AT WELL LOCATION 811 W. Mesquite Blvd
Mesquite NV

2. LOCATION SE ¼ NE ¼ Sec. 18 T. 13 N/S R. 71 E. Clark County
PERMIT NO. (Issued by Water Resources) | Parcel No. 001-18-607-008 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other MSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	0.4	0.4
Sand, Silty Sand		0.4	45.0	44.6
Clay, Siltyclay w/sand		45.0	65.0	20.0
MP Datum				
WGS 84				
MW-5 36°48.246N 114°05.975W				65'
MW-2R 36°48.239N 114°06.025W				65'
MW-7 36°48.204N 114°05.972W				64'
MW-6 36°48.202N 114°06.007W				60'

Date started 9/17, 2007
Date completed 9/21, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down Feet Below Static	Time (Hours)

DOWN
RECEIVED
OCT 02 2007
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 65/64/60 Feet Depth Cased 65/64/60 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11½	Inches	0	Feet	65	Feet
11½	Inches	0	Feet	64	Feet
11½	Inches	0	Feet	60	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.25		Sch 40 PVC	0	65
4.25		Sch 40 PVC	0	64
4.25		Sch 40 PVC	0	60

Perforations:
Type perforation Machine Slot
Size perforation .020
From 65 feet to 45 feet
From 64 feet to 44 feet
From 60 feet to 40 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 43/42/38
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 65/64/60 feet to 43/42/38 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services LLC (Contractor)
Address 7150 Pebble St. (Contractor)
Las Vegas NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
Signed (By driller performing actual drilling on site or contractor)
Date 9/27/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627