WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103923
Permit No.
Basin 212

1. OWNER Basic Remediation Company / Public Right of Way - City of Henderson NOTICE OF INTENT NO. 31828
MAILING ADDRESS 875 West Warm Springs Rd. Henderson NV, 89011
ADDRESS AT WELL LOCATION Approx 0.2 miles S of Intersection of Olivia Pkwy & Olivia Pkwy.
2. LOCATION SE ¼ SW ¼ Sec. 32 T. 21 N/S R. 63 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 16032499006 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Interbedded Silty Gravel & Silty Sand		0'	30'	30'
Muddy Creek Silty & Clay with Gypsum	✓	30'	75'	45'

NAD 83
682982.037400 East
3993714.623000

Date started 7-25-, 2007
Date completed 7-25-, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8	0	75

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	8 lb./ft	Sch 40 0.474"	+3'	45'

Perforations:
Type perforation Sch 40 Factory Cut
Size perforation .020
From 45' feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 43
Placement Method: ☐ Pumped ☑ Poured
Seal Type: 3/8 chip
☐ Neat Cement 43'-21'
☐ Cement Grout
☑ Concrete Grout 0'-2'

Gravel Packed: ☑ Yes ☐ No
From 43 feet to 75 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Co. (Contractor)
Address 7773 W. Seldon Lane (Contractor)
Peoria, AZ 85345
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2148
Signed Phillip E. C (By driller performing actual drilling on site or contractor)
Date 8-17-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627