WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103925
Permit No.
Basin 164A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Charles Whitley & Melissa Henry

NOTICE OF INTENT NO. 30995

1. OWNER Charlie and Melissa Henry Whitley
MAILING ADDRESS 6613 Wandering wind way 89128
ADDRESS AT WELL LOCATION State Hwy Rte 53 at Good Springs

2. LOCATION NW ¼ SW ¼ Sec. 25 T. 24 N/S R. 58 E. Clark County
PERMIT NO. (Issued by Water Resources) 202-25301-004 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TopSoil / Fill		0	1	1
Limestone		1	3	2
Red Sandstone		3	23	20
Cemented Gravel		23	25	2
Limestone & Red Sandstone		25	227	202
Fractured Limestone		227	236	9
Cemented Gravel		236	240	4
Limestone/Red SandStone		240	287	47
Soft Volcanic Rock		287	294	7
Red Sandstone/Limestone		294	439	145
Gray SandStone		439	464	25
Brn. Sand, Gray SandStone		464	532	68
Red Sand Stone & Brn Sand 530		532	533	1
Limestone & Red Sandstone		533	558	25
Fractured Limestone		558	578	20
Fractured Limestone/Sand		578	609	31
Sandstone Red & Lt Gray 638		609	638	29
Lt Gray SandStone		638	657	19
Gray Sandstone / Red Clay		657	680	23

RECEIVED
OCT 02 2007

Date started 8-06-, 2007
Date completed 9-26-, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		2 hrs
GPS		
35° 49' 48 N		
NAD83 115° 25' 32 W		

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	680 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	Factory		0	680

Perforations:
Type perforation Factory
Size perforation
From 440 feet to 680 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 0 feet to 680 feet

9. WATER LEVEL
Static water level 224 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name TDC Water Wells (Contractor)
Address 2870 W. Pebble Rd (Contractor)
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-27-07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627