WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103933
Permit No.
Basin 212

NOTICE OF INTENT NO. 34836

1. OWNER Pama Airport South LLC
MAILING ADDRESS 6565 Spencer #211, Las Vegas NV 89119
ADDRESS AT WELL LOCATION 2123 Pama Lane, Las Vegas NV

2. LOCATION SW ¼ NE ¼ Sec. 2 T. 22 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources | 177-02-603-015 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pulled system completely from well. System set at 105' well Depth 109'				
Abandoned 8" well to 109' well depth. Perforated well casing with mill Knife perforator from 109' to 80' where we encountered cement seal. Pumped in 9.4 yards of neat cement through a tremmie hose from the bottom of the well to the Surface. Inspected the next day, neat cement dropped 3 feet. Installed concrete grout from 3 feet to the surface.				
GPS 36°03'57N 115°07'25W Nad 83				
Plugging of Log 45502				

Date started 10/9/, 2007
Date complated 10/11/, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

OCT 12 2007

8. WELL CONSTRUCTION
Depth Drilled 109' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8				

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 29' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name TDC Drilling Contractor
Address 2870 W Pebble Rd, Contractor
Las Vegas, NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2333-T1
Signed Tom Willis
By driller performing actual drilling on site or contractor
Date 10-12-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627