

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34837

1. OWNER Pama Airport South LLC ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6565 Spencer #211 2053 Pama Lane, Las
Las Vegas NV 89119 Vegas NV
 2. LOCATION SW 1/4 NE 1/4 Sec. 2 T. 22 N. R. 61 E Clark County
 PERMIT NO. 177-02-603-014 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Pulled system completely from the well. System set at 84' well depth 210'				
Abandoned 8" well to 210' well depth. Perforated well casing with mill knife perforator from 210' to 50' where we encountered cement seal.				
Pumped in 24 yard of neat cement through a tremmie hose from the bottom of the well to the surface, completely filling the well.				
GPS 36° 03' 57" N NAD 83 115° 07' 27" W				

8. WELL CONSTRUCTION
 Depth Drilled 210 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8				

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 10/9/2007
 Date completed 10/11/2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

OCT 12 2007

9. WATER LEVEL
 Static water level 28 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name TDC Drilling Contractor
 Address 2870 W Pebble Rd Contractor
Las Vegas NV 89123
 Nevada contractor's license number 59948
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2353-T1
 Signed Sam Will
 By driller performing actual drilling on site or contractor
 Date 10-12-07