WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103935
Permit No.
Basin 212

NOTICE OF INTENT NO. 34838

1. OWNER Pama Airport South LLC
MAILING ADDRESS 6565 Spencer #211 Las Vegas NV 89119
ADDRESS AT WELL LOCATION 2029 Pama Ln, Las Vegas, NV

2. LOCATION SW ¼ NE ¼ Sec. 2 T 22 N/S R 61 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 177-02-603-002 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
No System in well.				
Removed well seal. Abandoned 8" well to 93 feet.				
Perforated well casing from 93' to 50', where we encounted cement seal. Perforated casing with mill knife perforator.				
Pumped in 6.7 yards of neat cement through a tremmie hose, from the bottom of the well to the surface, completely filling the well.				
GPS 36° 03' 57N NAD 83 115° 07' 27 W				

Date started 10 / 9 / 2007
Date complated 10 / 11 / 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

OCT 12 2007

8. WELL CONSTRUCTION
Depth Drilled 93' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8				

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 27' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name TDC Drilling (Contractor)
Address 2870 W Pebble Rd (Contractor)
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2333-71
Signed (By driller performing actual drilling on site or contractor)
Date 10 / 12 / 07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627