

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 163944
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.310

NOTICE OF INTENT NO. 30592
 ADDRESS AT WELL LOCATION 1230 W. Gee St.

1. OWNER **Tom & Virginia Delaney**
 MAILING ADDRESS _____

2. LOCATION **NE 1/4 NE 1/4 Sec 32 T 19-S N R 53 E** **Nye** County
 PERMIT NO. 41-571-25 **Golden Springs Ranch, Ut: 7 Lot: 57**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown Clay/Gran. Caliche		4	14	10
Brown Clay		14	46	32
Brown Clay/Caliche		46	63	17
Brown Clay		63	85	22
Brown Clay/Caliche	X	85	200	115
WGS 84				
Location:				
N 36°15.782'				
W 116° 02.206'				
Elevation: 2563'				
Accuracy: 14'				

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	0 Feet <u>200</u> Feet
Inches	Feet Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.92	.28	0	200

Perforations:
 Type perforation **Saw Cut**
 Size perforation **1/4" width 8" long**

From	To
160 feet	200 feet
feet	feet
feet	feet
feet	feet
feet	feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL

Static water level 61 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____


10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **JIM PIKE WELL DRILLING, LLC.**
 (CONTRACTOR)

Date started Oct. 21, 20 07
 Date completed Oct. 22, 20 07

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

Address **P.O. BOX 56**
 (CONTRACTOR)
PAHRUMP, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board **17563A**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1324**
 Signed 
 By driller performing actual drilling on site or contractor
 Date **October 24, 2007**