



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31239

1. OWNER TRI GLOBAL LLC ADDRESS AT WELL LOCATION 4390 W CHARLESTON AVE.  
 MAILING ADDRESS 4390 W CHARLESTON PARK AVE.  
PAHRUMP, NV

2. LOCATION SW 1/4 SE 1/4 Sec. 14 T 20S N/S R 52E E NYE County  
 PERMIT NO. 41-503-13 GOLDEN SPRING RANCH 38  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	18	18
CALICHE		18	35	17
CLAY		35	67	32
CALICHE	WB	67	78	11
CLAY		78	105	27
CALICHE	WB	105	115	10
CLAY		115	146	31
CALICHE	WB	146	165	19
CLAY		165	185	20
CALICHE	WB	185	200	15

WGS 84  
 N 36 DEGREES 12.334  
 W 116 DEGREES 05.525

Date started 11/7/2007, 19  
 Date completed 11/8/2007, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 200 Feet  
10 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.36	.250	0	200

Perforations:  
 Type perforation SAWCUT  
 Size perforation 1/8 X 3

From <u>100</u> feet to <u>120</u> feet
From <u>140</u> feet to <u>160</u> feet
From <u>180</u> feet to <u>200</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 63 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor  
 Address 1220 E MANSE RD Contractor  
PAHRUMP, NV. 89048  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on-site of contractor  
 Date 11/8/2007