

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31232

1. OWNER ED FRAZIER ADDRESS AT WELL LOCATION 6230 S VICKI ANN RD
 MAILING ADDRESS 6230 S VICKI ANN RD
PAHRUMP, NV

2. LOCATION SE 1/4 NE 1/4 Sec. 14 T 21S N/S R 53E E NYE County
 PERMIT NO. 44-631-04 Issued by Water Resources Parcel No. STARDUST Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	5	5
CALICHE		5	30	25
CLAY		30	76	46
CALICHE	WB	76	95	19
CLAY		95	140	45
CALICHE	WB	140	155	15
CLAY		155	170	15
CALICHE	WB	170	186	16
CLAY		186	210	24
CALICHE	WB	210	230	20
CLAY		230	245	15
CALICHE	WB	245	268	23
CLAY		268	280	12
CALICHE	WB	280	300	20

WGS84
 N 36 DEGREES 07.719
 W 115 DEGREES 58.562

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>300</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From 200 feet to 300 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 10/17/2007 19
 Date completed 10/17/2007 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 10/18/2007