WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104006
Permit No.
Basin 162

NOTICE OF INTENT NO. 31228

1. OWNER LESLIE CROOKS
MAILING ADDRESS 6190 S PAHRUMP VALLEY BLVD
PAHRUMP, NV

ADDRESS AT WELL LOCATION 6190 S PAHRUMP VALLEY BLVD

2. LOCATION NE 1/4 NE 1/4 Sec. 15 T 21S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 44-691-01 (Parcel No.) MESA OESTE ESTATES (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING 140 FT 8"				
STEEL WELL 140'				
CLAY		140	156	16
CALICHE	WB	156	175	19
CLAY		175	187	12
CALICHE	WB	187	205	18
CLAY		205	220	15
CALICHE	WB	220	230	10
CLAY		230	240	10
WGS84				
N 36 DEGREES 07.695				
W 115 DEGREES 59.584				

DCNR/DWR
RECEIVED
SEP 19 2007
LAS VEGAS OFFICE

Date started 9/7/2007 , 19__
Date completed 9/7/2007 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	140	Feet
7 7/8	Inches	140	Feet	240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.36	.248	0	240

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From		feet to	feet
From	100	feet to	120 feet
From	140	feet to	160 feet
From	180	feet to	200 feet
From		feet to	feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal EXISTING
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 9/11/2007

USE ADDITIONAL SHEETS IF NECESSARY