

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31230

1. OWNER **JIM SCHICT**
 MAILING ADDRESS **6551 PAULA DR. PAHRUMP, NV**
 ADDRESS AT WELL LOCATION **6551 PAULA DR**

2. LOCATION **NE** 1/4 **SW** 1/4 Sec. **14** T **21S** N/S R **53E** E **NYE** County
 PERMIT NO. **44-732-05** **MESA OESTE #3**
issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING 8" STEEL WELL 140'				
CLAY		140	145	5
CALICHE	WB	145	160	15
CLAY		160	185	25
CALICHE	WB	185	195	10
CLAY		195	215	20
CALICHE	WB	215	237	22
CLAY		237	240	3
WGS84				
N36 DEGREES 07.411				
W 115 DEGREES 59.095				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From To
EXISTING 8 Inches Feet Feet
7 7/8 Inches **140** Feet **240** Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/FT (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.36	.248	0	240

Perforations:
 Type perforation **SAWCUT**
 Size perforation **1/8 X 3**

From **140** feet to **240** feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal **EXISTING**
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From **140** feet to **240** feet

9. WATER LEVEL
 Static water level **125** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
 Contractor

Date started **10/8/2007**, 19____
 Date completed **10/8/2007**, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Address **1220 E MANSE RD** Contractor
PAHRUMP, NV, 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**
 Signed _____
 By driller performing actual drilling on-site or contractor
 Date **10/10/2007**