39° 29.971 N / 118° 52.122 W WGS84

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104038
Permit No.
Basin 101

NOTICE OF INTENT NO. 56195

1. OWNER JKG
MAILING ADDRESS

ADDRESS AT WELL LOCATION ~~5830~~ 5630 Caleb Rd (41 Lot)

2. LOCATION ~~NW~~ SE ¼ NW ¼ Sec. 20 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 008-173-09 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Gravels		1	17	
Clay		17	43	
Sand Gravels Beige		43	63	
Clay Sand (Black)		63	92	
Clay Black		92	96	
Gravels Brey		96	115	
Clay Black		115	120	
N 39.499617				
W 118.867720 NAD27				

RECEIVED 2007 JAN -4 AM 10:59 STATE ENGINEERS OFFICE

Date started 12/20/06, 20
Date complated 12/20/06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3 hrs

8. WELL CONSTRUCTION
Depth Drilled 120' Feet Depth Cased 120' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	120' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	1.88	1	20'
6 5/8	SH40	PVC	20	120'

Perforations:
Type perforation Machine Perf
Size perforation 1/8 x 2 1/2 x 3# rows
From 97 feet to 106 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120' feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leach Drilling
Contractor
Address P.O. 599
Contractor
SS NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 876

Signed [signature]
By driller performing actual drilling on site or contractor

Date 12/27/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627